

Aboveground Storage Tanks (AST)

**Enhanced Vapor Recovery
(EVR)**

Presented on 04/16/09



Topics

- Overview
- Regulations
- AST EVR Deadlines
- Standing Loss Control Overview
- Standing Loss Control Certification
- Phase I AST Certification
- Phase II and ISD AST Certification
- Summary



Overview of AST Program

Board approved new vapor recovery certification requirements to reduce emissions from AST's in 2007

● Standing Loss Control Certification

◆ New to the Certification Matrix

● Phase I AST Certification

◆ Fueling of aboveground storage tanks

● Phase II and ISD AST Certification

◆ Refueling of vehicle fuel tanks

} *Similar to the existing
EVR requirements for
USTs*




Regulations

(current)

 Adopted by the Board on May 2, 2008

 **CP-206** – *Certification Procedure for Vapor Recovery Systems at GDFs Using Aboveground Storage Tanks (references to CP 201)*

 **AST Test Procedures:**

 **TP-206.1** – *Determination of Emission Factor for Standing Loss Control*

 **TP-206.2** – *Determination of Emission Factor for Standing Loss Control Using Processors*

 **TP-206.3** – *Determination of Static Pressure Performance of Vapor Recovery Systems at GDF with ASTs*



AST EVR Deadlines

- Executive Order G-70-213 issued on December 31, 2009 extended all the AST EVR deadlines
 - Original effective and operative date was January 1, 2009
 - Extensions were necessary since there were no systems commercially available
 - New effective and operative dates are as follows:
 - ◆ Standing Loss Control: April 1, 2009
 - ◆ Phase I: January 1, 2010
 - ◆ Phase II and ISD: January 1, 2011
- Major modification and/or replacement of ASTs require upgrading to current EVR specifications
- Existing ASTs have four years from the new effective dates above to comply



Standing Loss Control Overview

■ Standing Loss Control

- Controls emissions during idle periods – Heating of the tanks by the sun causes the fuel to volatize and vent into the atmosphere

■ Standing Loss Control is certified based on one of the following approaches:

- *Performance* – Tests all GDF components as a system, components are certified together as a system
- *Design* – Tests GDF components independently. Once the components are certified, they are added to a consolidated EO. Mixing and matching of components is allowed.



Standing Loss Control Overview (cont.)

- Standing Loss Control specifications and requirements
 - Existing Installations (P/V Valve and approved paint or shade) – Emission Factor Requirement of ≤ 2.26 lbs/1000 gallons ullage/day
 - New Installations (P/V Valve and insulation) – Emission Factor Requirement of ≤ 0.57 lbs/1000 gallons ullage/day

- Standing Loss Control certification requirements
 - Minimum requirements – 30 consecutive days during the summer months (June 1 – September 30), at least seven of the 30-days shall have a peak temperature between 90 F - 105 F. Testing outside of the above dates may be approved by ARB if the temperature criteria are met



Standing Loss Certification (typical setup)



04/16/09



Standing Loss Control Certification

Executive Orders

- VR-301-A – Standing Loss Control Vapor Recovery System for *Existing Installations* of Aboveground Storage Tanks
 - Approved by Board on April 2, 2009
 - White Paint (*OPW is the Applicant*) for Existing ASTs
 - Existing SuperVault MH Series and Fireguard ASTs
(*Modern Custom Fabrication, Inc and Steel Tank Institute are the applicants respectively*)
 - Available soon at <http://www.arb.ca.gov/vapor/ast/ast.htm>

- VR-302-A – Standing Loss Control Vapor Recovery System for *New Installations* of Aboveground Storage Tanks
 - Approved by Board on April 2, 2009
 - New Installations of SuperVault MH Series and Fireguard ASTs
(*Modern Custom Fabrication, Inc and Steel Tank Institute are the applicants respectively*)
 - Available soon at <http://www.arb.ca.gov/vapor/ast/ast.htm>



Standing Loss Control Certification

Current Test Site

ConVault ASTs

- Location: Denair, California
 - ◆ System: Husky 5885 PV Valve installed on a 250-gallon protected ConVault AST
- Status: 30-day operational test period completed.
- Standing Loss Certification completed outside the summer month requirements set forth in CP-206.
- Alternative Test Procedure was submitted by applicant and approved by ARB to allow the use of an environmentally controlled chamber to meet the ambient temperature requirements set forth in CP-206.
- Temperature profile from this test site is similar to other Standing Loss Certifications that were conducted during the summer month



ConVault Standing Loss Control

Denair, CA



04/16/09

11



Phase I AST EVR Certification

Differences between Phase I AST and Phase I UST

- Emergency vents
- Over-fill prevention valve
- Non-rotatable vapor and product adaptors
- Mechanical tank gauge



Phase I AST EVR Certification

Current Test Site

OPW Phase I EVR for AST

- Location: Firebaugh, California
 - ◆ System: OPW Phase I EVR, Husky 5885 PV Valve installed on a 550-gallon single-wall AST painted with an approved white paint listed in VR-301-A
- Seal Date: January 9, 2009
- Status: Within 180-day operational test period



OPW Phase I EVR: Firebaugh, CA



04/16/09

14



Phase II and ISD AST EVR Certification

- Various Phase II manufacturers have expressed interest in certifying their systems.
 - Can't Start Phase II until Phase I is completed



Questions?



04/16/09





Contacts



Sam Vogt

- (916) 322-8922
- svogt@arb.ca.gov



Donielle Jackson

- (916) 445-9308
- djackso@arb.ca.gov



Tahir Muhammad

- (916) 449-5289
- tmuhamma@arb.ca.gov