



air pollution control district
SANTA BARBARA COUNTY

DRAFT

Permit to Operate 16176

Page 1 of 8

EQUIPMENT OWNER:

Marian Medical Center

EQUIPMENT OPERATOR:

Marian Medical Center

EQUIPMENT LOCATION:

525 E. Plaza Drive, Santa Maria

STATIONARY SOURCE/FACILITY:

Marian Medical Outpatient Care Center

SSID: 10478

FID: 10612

EQUIPMENT DESCRIPTION:

In-use diesel-fired emergency standby generator engine(s) as listed in the table at the end of this permit.

PROJECT/PROCESS DESCRIPTION:

The generator(s) subject to this permit provide electrical backup power in times of emergencies as defined by the State's *Airborne Toxics Control Measure for Stationary Compression Ignition Engines* (ATCM). This ATCM (CCR Section 93115, Title 17) limits annual generator maintenance and testing hours to 40 hours per year with no limitation for emergency use. Definitions of the terms "*maintenance and testing*" and "*emergency use*" are found in the ATCM and the District's webpage <http://www.ourair.org/dice-atcm/>.

DRAFT

Permit to Operate 16176

Page 2 of 8

CONDITIONS:

1. **Emission Limitations.** The mass emissions from the equipment permitted herein shall not exceed the values listed in Table 1. Compliance shall be based on the operational, monitoring, recordkeeping and reporting conditions of this permit.

2. **Operational Restrictions.** The equipment permitted herein is subject to the following operational restrictions. The equipment may operate as many hours as necessary for emergency use, as defined in the ATCM¹.
 - a. Maintenance & Testing Use Limit: The in-use stationary emergency standby diesel-fueled engine(s) shall not be operated for more than the hours listed in the attached equipment list for maintenance and testing² purposes.

 - b. Impending Rotating Outage Use: The in-use stationary emergency standby diesel-fueled engine(s) may be operated in response to the notification of an impending rotating outage if all the conditions cited in the ATCM are met.

 - c. Fuel and Fuel Additive Requirements: The permittee may only add fuel and/or fuel additives that comply with the ATCM to the engine or to any fuel tank directly attached to the engine.

 - d. Near-School Provisions: The stationary emergency standby diesel-fueled engine(s) shall not be operated for non-emergency use, including maintenance and testing, between 7:30 a.m. and 3:30 p.m. on days school is in session.

3. **Monitoring.** The equipment permitted herein is subject to the following monitoring requirements:
 - a. Non-Resettable Hour Meter: Each in-use stationary emergency standby diesel-fueled engine(s) shall be equipped with a non-resettable hour meter with a minimum display capability of 9,999 hours, unless the District has determined (in writing) that a non-resettable hour meter with a different minimum display capability is appropriate in consideration of the historical use of the engine and the owner or operator's compliance history.

¹ As used in the permit, "ATCM" means Section 93115, Title 17, California Code of Regulations. Airborne Toxic Control Measure for Stationary Compression Ignition (CI) Engines

² "maintenance and testing" is defined in the ATCM and may also be found on the District webpage at http://www.ourair.org/wp-content/uploads/ES_MT_DICE_Definitions.pdf

DRAFT

Permit to Operate 16176

Page 3 of 8

4. **Recordkeeping.** The permittee shall record and maintain the information listed below. Log entries shall be retained for a minimum of 36 months from the date of entry. Log entries made within 24 months of the most recent entry shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request. Log entries made from 25 to 36 months from most recent entry shall be made available to District staff within 5 working days from request. District Form ENF-92 (*Diesel-Fired Emergency Standby Engine Recordkeeping Form*) can be used for this requirement.
 - a. emergency use hours of operation.
 - b. maintenance and testing hours of operation.
 - c. hours of operation for emission testing to show compliance with the ATCM {if specifically allowed for under this permit}.
 - d. hours of operation to comply with the requirements of NFPA for healthcare facilities (if applicable).
 - e. hours of operation for all uses other than those specified in items (a) – (d) above along with a description of what those hours were for.
 - f. fuel purchase records that demonstrate that only fuel meeting the requirements of the ATCM is purchased and added to each emergency standby engine, or to any fuel tank directly attached to each emergency standby engine.
5. **Reporting.** By March 1 of each year, a written report documenting compliance with the terms and conditions of this permit and the ATCM for the previous calendar year shall be provided by the permittee to the District (Attn: *Annual Report Coordinator*). All logs and other basic source data not included in the report shall be made available to the District upon request. The report shall include the information required in the Recordkeeping Condition above.
6. **Temporary Engine Replacements - DICE ATCM.** Any reciprocating internal combustion engine subject to this permit and the stationary diesel ATCM may be temporarily replaced only if the requirements (a – h) listed herein are satisfied.
 - a. The permitted engine that is being temporarily replaced is in need of routine repair or maintenance.
 - b. The permitted engine does not have a cracked block, unless the block will be replaced under manufacturer's warranty.
 - c. Replacement parts are available for the permitted engine.

DRAFT

Permit to Operate 16176

Page 4 of 8

- d. The permitted engine is returned to its original service within 180 days of installation of the temporary engine.
- e. The temporary replacement engine has the same or lower manufacturer rated horsepower and same or lower potential to emit of each pollutant as the permitted engine. At the written request of the permittee, the District may approve a replacement engine with a larger rated horsepower if the proposed temporary engine has manufacturer guaranteed emissions (for a brand new engine) or source test data (for a previously used engine) less than or equal to the permitted engine.
- f. The temporary replacement engine shall comply with all rules and permit requirements that apply to the permitted engine.
- g. For each permitted engine to be temporarily replaced, the permittee shall submit a completed *Temporary IC Engine Replacement Notification* form (Form ENF-94) within 14 days of the temporary engine being installed. This form may be sent hardcopy, or can be e-mailed (e-mail: enr@sbcapcd.org) to the District (Attn: Engineering Supervisor).
- h. Within 14 days of returning the original permitted engine to service, the permittee shall submit a completed *Temporary IC Engine Replacement Report* form (Form ENF-95). This form may be sent hardcopy, or can be e-mailed (e-mail: enr@sbcapcd.org) to the District (Attn: Engineering Supervisor).

Any engine in temporary replacement service shall be immediately shut down if the District determines that the requirements of this condition have not been met. If the requirements of this condition are not met, the permittee must obtain an ATC before installing or operating a temporary replacement engine.

- 7. **Permanent Engine Replacements.** The permittee may install a new engine in place of an engine permitted herein without first obtaining an ATC only if the requirements (a – f) listed herein are satisfied.
 - a. The permitted stationary diesel-fueled engine is an E/S engine, a firewater pump engine or an engine used for an essential public service (as defined by the District).
 - b. The permitted engine breaks down, cannot be repaired, and needs to be replaced by a new permanent engine.
 - c. The facility provides “good cause” (in writing) for the need to install a new permanent engine before an ATC can be obtained for a new engine.

DRAFT

Permit to Operate 16176

Page 5 of 8

- d. The new permanent engine must comply with the requirements of the ATCM for new engines. A temporary replacement engine may be used while the new permanent engine is being procured only if it meets the requirements of the *Temporary Engine Replacements - DICE ATCM* permit condition.
- e. An ATC application for the new permanent engine must be submitted to the District within 15 days of the existing engine being replaced and the ATC must be obtained no later than 180 days from the date of engine replacement (these timelines include the use of a temporary engine).
- f. For each new permanent engine installed pursuant to this condition, the permittee shall submit a completed *Permanent IC Engine Replacement Notification* form (Form ENF-96) within 14 days of the new engine being installed. This form may be sent hardcopy, or can be e-mailed (e-mail: engr@sbcapcd.org) to the District (Attn: Engineering Supervisor).

Any engine installed pursuant to this condition shall be immediately shut down if the District determines that the requirements of this condition have not been met.

- 8. **Notification of Non-Compliance.** Owners or operators who have determined that they are operating their stationary diesel-fueled CI engine(s) in violation of the requirements specified in the ATCM shall notify the District immediately upon detection of the violation and shall be subject to District enforcement action.
- 9. **Notification of Loss of Exemption.** Owners or operators of in-use stationary diesel-fueled CI engines who are exempt from all or part of the requirements of the ATCM shall notify the District within five days after they become aware that the exemption no longer applies and shall demonstrate compliance within 180 days after the date the exemption no longer applies.
- 10. **Enrollment in a DRP/ISC.** Owners or operators shall obtain an ATC before enrolling a stationary diesel-fueled CI engine rated over 50 bhp in a Demand Response Program/Interruptible Service Contract (as defined in the ATCM) for the first time.
- 11. **Consistency with Analysis.** Operation under this permit shall be conducted consistent with all data, specifications and assumptions included with the application and supplements thereof (as documented in the District's project file) and the District's analyses under which this permit is issued as documented in the Permit Evaluation prepared for and issued with the permit.
- 12. **Equipment Maintenance.** The equipment listed in this permit shall be properly maintained and kept in good condition at all times. The equipment manufacturer's maintenance manual, maintenance procedures and/or maintenance checklists (if any) shall be kept on site.
- 13. **Compliance.** Nothing contained within this permit shall be construed as allowing the violation of any local, state or federal rules, regulations, air quality standards or increments.

DRAFT

Permit to Operate 16176

Page 6 of 8

14. **Severability.** In the event that any condition herein is determined to be invalid, all other conditions shall remain in force.
15. **Conflict Between Permits.** The requirements or limits that are more protective of air quality shall apply if any conflict arises between the requirements and limits of this permit and any other permitting actions associated with the equipment permitted herein.
16. **Access to Records and Facilities.** As to any condition that requires for its effective enforcement the inspection of records or facilities by the District or its agents, the permittee shall make such records available or provide access to such facilities upon notice from the District. Access shall mean access consistent with California Health and Safety Code Section 41510 and Clean Air Act Section 114A.
17. **Equipment Identification.** Identifying tag(s) or name plate(s) shall be displayed on the equipment to show manufacturer, model number, and serial number. The tag(s) or plate(s) shall be issued by the manufacturer and shall be affixed to the equipment in a permanent and conspicuous position.
18. **Emission Factor Revisions.** The District may update the emission factors for any calculation based on USEPA AP-42 or District emission factors at the next permit modification or permit reevaluation to account for USEPA and/or District revisions to the underlying emission factors.
19. **Transfer of Owner/Operator.** This permit is only valid for the owner and operator listed on this permit unless a *Transfer of Owner/Operator* application has been applied for and received by the District. Any transfer of ownership or change in operator shall be done in a manner as specified in District Rule 203. District Form -01T and the appropriate filing fee shall be submitted to the District within 30 days of the transfer.
20. **Reimbursement of Costs.** N/A

AIR POLLUTION CONTROL OFFICER

DATE

DRAFT

Permit to Operate 16176

Page 7 of 8

Attachments:

- Table 1 – Mass Emission Limits
- Table 2 – Emission Standards
- Permit Equipment List
- Permit Evaluation for Permit to Operate 16176

Notes:

- Reevaluation Due Date: September 2026.
- ATCM information can be located online at <http://www.ourair.org/dice-atcm/>
- Detailed recordkeeping is required. See Form ENF -92 at the above webpage.
- Stationary sources are subject to an annual emission fee (see Fee Schedule B-3 of Rule 210).
- Annual reports are due by March 1st of each year.
- This permit supersedes Reeval 11743-R5

DRAFT

Permit to Operate 16176

TABLE 1. MASS EMISSION LIMITS

Device ID #	NO _x		ROC		CO		SO _x		PM		PM10		PM2.5	
	lb/day	tpy	lb/day	tpy	lb/day	tpy	lb/day	tpy	lb/day	tpy	lb/day	tpy	lb/day	tpy
106632	32.17	0.13	2.56	0.01	6.85	0.03	0.01	0.01	2.28	0.01	2.28	0.01	2.28	0.01

TABLE 2. EMISSION FACTORS (g/bhp-hr)

Device ID #	NO _x	ROC	CO	SO _x	PM	PM10	PM2.5
106638	14.10	1.12	3.00	0.01	1.00	1.00	1.00

Table Notes:

- (a) Mass emission limits based on allowable maintenance and testing hours.
- (b) NO_x as NO₂. SO_x as SO₂.
- (c) Device ID # from permit equipment list.
- (d) lb/day = pounds per day. tpy = tons per year
- (e) Emission data that round down to 0.00 has been set to a default of 0.01.
- (f) Calculated using the default SBCAPCD diesel engine emission factors available on the District website here: <http://www.ourair.org/dice/emission-factors/>.

PERMIT EQUIPMENT LIST

<i>Device ID #</i>	106632	<i>Maximum Rated BHP</i>	207
<i>Device Name</i>	E/S Diesel Generator	<i>Serial Number</i>	45173365
<i>Engine Use</i>	Electrical Power	<i>EPA Engine Family Name</i>	n/a
<i>Manufacturer</i>	Cummins	<i>Operator ID</i>	Plaza Gen
<i>Model Year</i>	1995	<i>Fuel Type</i>	CARB Diesel - ULSD
<i>Model</i>	6CT8.3-G2		
<i>DRP/ISC?</i>	No	<i>Healthcare Facility?</i>	Yes
<i>Daily Hours</i>	5.00	<i>Annual Hours</i>	40
<i>Location</i>			
<i>Note</i>			
<i>Device Description</i>	Tier 0 207 bhp diesel-fired, turbocharged, backup generator.		



air pollution control district
SANTA BARBARA COUNTY

DRAFT

PERMIT EVALUATION FOR
PERMIT TO OPERATE 16176

Page 1 of 3

1.0 BACKGROUND:

This permit addresses requirements of the State's Airborne Toxic Control Measure for Stationary Compression Ignition Engines (DICE ATCM). On March 17, 2005, District Rule 202 *{Exemptions to Rule 201}* was revised to remove the compression-ignited engine (e.g., diesel) permit exemption for units rated over 50 brake horsepower (bhp). That exemption was removed to allow the District to implement the DICE ATCM. This permit covers In-Use emergency standby (E/S) generators operated at healthcare facilities with annual maintenance and testing operation limited to 40 hours or less. This permit authorizes an increase to the daily permitted hours of operation from 2 hours per day to 5 hours per day in order to accommodate annual load testing requirements.

2.0 DICE ATCM COMPLIANCE

Owners of In-Use Stationary DICE E/S generators are subject to the requirements of Table 2 of the ATCM. By limiting annual maintenance and testing hours to 20 hours or less, these engines are not required to meet any new emission standards (i.e., engine retrofits are not required). Healthcare facilities are authorized to operate for an additional 20 hours/year, totaling 40 hours/year per section (e)(2)(B)a.I.1. The ATCM does require that the hours of operation be monitored with a non-resettable hour meter, that CARB Diesel Fuel be used (or approved alternative) and that detailed records of use be recorded and reported.

The Federal NESHAP for reciprocating internal combustion engines (RICE NESHAP) established inspection and maintenance requirements for emergency standby diesel engines. Engines at residential, institutional, and commercial facilities are exempt from these new requirements. Additionally, engines constructed after 2005 are subject to federal New Source Performance Standards (NSPS) and are not subject to further requirements under NESHAP. The engine on this permit is exempt from the requirements of the RICE NESHAP because the engine is located at an institutional facility.

3.0 EMISSIONS

Mass emission estimates are based on the maximum allowed hours for maintenance and testing. Emissions are determined by the following equations:

$$\begin{aligned} E1, \text{ lb/day} &= \text{Engine Rating (bhp)} * \text{EF (g/bhp-hr)} * \text{Daily Hours (hr/day)} * (\text{lb}/453.6 \text{ g}) \\ E2, \text{ tpy} &= \text{Engine Rating (bhp)} * \text{EF (g/bhp-hr)} * \text{Annual Hours (hr/yr)} * (\text{lb}/453.6 \text{ g}) * (\text{ton}/2000 \text{ lb}) \end{aligned}$$

The emission factors (EF) were chosen based on each engine's rating and age. Default emission factors are documented on the District's webpage at <http://www.ourair.org/dice/emission-factors/>. Daily hours are 5 hours per day (re: ATCM FAQ Ver 1.5 #32), as requested by the applicant.

4.0 REEVALUATION REVIEW (not applicable)

DRAFT

**PERMIT EVALUATION FOR
PERMIT TO OPERATE 16176**

5.0 AQIA

The project is not subject to the Air Quality Impact Analysis requirements of Regulation VIII.

6.0 OFFSETS/ERCs

Offsets: The emission offset thresholds of Regulation VIII are not exceeded.

ERCs: This source does not generate emission reduction credits.

7.0 AIR TOXICS

An air toxics health risk assessment was not performed for this permitting action because only the daily emissions have increased. Health risk assessments are based on annual and hourly pollutant emission rates and state-approved health risk data. Therefore, the authorized increase in daily emissions does not affect health risk.

8.0 CEQA / LEAD AGENCY

This project is exempt from CEQA pursuant to the Environmental Review Guidelines for the Santa Barbara County APCD (revised April 30, 2015). Appendix A (*APCD Projects Exempt from CEQA and Equipment or Operations Exempt from CEQA*) provides an exemption specifically for permits to operate and reevaluations thereof. No further action is necessary.

9.0 SCHOOL NOTIFICATION

A school notice pursuant to the requirements of H&SC §42301.6 was required as the project site is located within 1,000 feet of Isaac Miller Elementary School. A notice to the parents of the students, and residences and businesses within 1,000 feet of the project will be mailed.

10.0 PUBLIC and AGENCY NOTIFICATION PROCESS/COMMENTS ON DRAFT PERMIT

10.1 This project is subject to a 30-day public notice.

10.2 Draft comments, if any are submitted, may be found in this section of the final permit.

11.0 FEE DETERMINATION

Fees for this permit were assessed pursuant to Schedule F.2 of Rule 210.

12.0 RECOMMENDATION

It is recommended that this permit be granted with the conditions as specified in the permit.

AQ Engineer/Technician	Date	Supervisor	Date
------------------------	------	------------	------

DRAFT

**PERMIT EVALUATION FOR
PERMIT TO OPERATE 16176**

Page 3 of 3

13.0 ATTACHMENT(S)

- A. IDS Tables
- B. Fee Statement

DRAFT

Permit to Operate 16176

ATTACHMENT A
IDS Tables

PERMIT POTENTIAL TO EMIT

	NO _x	ROC	CO	SO _x	PM	PM ₁₀	PM _{2.5}
lb/day	32.17	2.56	6.85	0.01	2.28	2.28	2.28
lb/hr							
TPQ							
TPY	0.13	0.01	0.03	0.01	0.01	0.01	0.01

FACILITY POTENTIAL TO EMIT

	NO _x	ROC	CO	SO _x	PM	PM ₁₀	PM _{2.5}
lb/day	32.17	2.56	6.85	0.01	2.28	2.28	2.28
lb/hr							
TPQ							
TPY	0.13	0.01	0.03	0.01	0.01	0.01	0.01

STATIONARY SOURCE POTENTIAL TO EMIT

	NO _x	ROC	CO	SO _x	PM	PM ₁₀	PM _{2.5}
lb/day	32.17	2.56	6.85	0.01	2.28	2.28	2.28
lb/hr							
TPQ							
TPY	0.13	0.01	0.03	0.01	0.01	0.01	0.01

Notes:

- (1) Emissions in these tables are from IDS.
- (2) Because of rounding, values in these tables shown as 0.00 are less than 0.005, but greater than zero.

DRAFT

Permit to Operate 16176

ATTACHMENT B
Fee Statement



air pollution control district
SANTA BARBARA COUNTY

FEE STATEMENT

PTO No. 16176

FID: 10612 Marian Medical Outpatient Care Center / SSID: 10478

Permit Fee

Administrative Change \$535.00

Fee Statement Grand Total = \$535

Notes:

- (1) Fee Schedule Items are listed in District Rule 210, Fee Schedule "A".
- (2) The term "Units" refers to the unit of measure defined in the Fee Schedule.