

**Please note that each tab is for a different category of engine. You can either refer to the descriptive header at the top of each page to determine your engine type, or refer to the Applicability Flowchart under "Implementation Information" at <http://www.epa.gov/ttn/atw/rice/ricepg.html>**

<b>Date of Revision</b>	<b>Description of Revision</b>
12/3/2010	Table of Requirements was revised to correct the compliance date in cell C18 of STEP 1a for existing stationary engines >500 HP at area sources to 10/19/2013.
2/22/2011	Revisions to change tab names. Under Step 1a, "Footnote 1 of Table 2d" corrected to read "Footnote 2 of Table 2d." Compliance date for residential/commercial/institutional emergency engines clarified, as it depends on whether the engine is CI or SI. The compliance date is 10/19/13 for SI engines and 5/3/13 for CI engines.

Engine Category	Date Constructed	Compliance Date	Emission Limitations	Operating Limitations	Fuel Requirements	Performance Tests	Monitoring, Installation, Collection, Operation and Maintenance Requirements	Initial Compliance	Continuous Compliance	Notification Requirements	Recordkeeping Requirements	Reporting Requirements	General Provisions (40 CFR part 63)
<b>Stationary RICE at Area Sources</b>													
<b>STEP 1a - Existing Area Sources</b>													
<b>Existing Stationary Engine ≤500 HP Located at Area Sources of HAP</b>													
Emergency CI	Before 6/12/2006	5/3/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (f), (h), (i)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c))	Footnote 2 of Table 2d	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency CI 300<HP≤500	Before 6/12/2006	5/3/2013	63.6603 Table 2d	No Requirements	>300 HP with displacement <30 l/cyl: 63.6604	63.6612 63.6620 Table 4 Table 5	63.6625(h) ≥300 HP: 63.6625(g)	63.6630 Table 5	63.6605 63.6640	63.6645	63.6655 (except 63.6655(c) and (f))	63.6650 (except 63.6650(g))	Yes
Non-Emergency CI ≤300 HP	Before 6/12/2006	5/3/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (i)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Emergency SI	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (f), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c))	Footnote 2 of Table 2d	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency SI 4SLB	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency SI 2SLB	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency SI 4SRB	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency Landfill/Digester Gas	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Residential/Commerical/Institutional Emergency CI	Before 6/12/2006	5/3/2013	These engines are subject to the requirements in 40 CFR 63.6640(f). No other requirements apply.										
Residential/Commerical/Institutional Emergency SI	Before 6/12/2006	10/19/2013	These engines are subject to the requirements in 40 CFR 63.6640(f). No other requirements apply.										

Engine Category	Date Constructed	Compliance Date	Emission Limitations	Operating Limitations	Fuel Requirements	Performance Tests	Monitoring, Installation, Collection, Operation and Maintenance Requirements	Initial Compliance	Continuous Compliance	Notification Requirements	Recordkeeping Requirements	Reporting Requirements	General Provisions (40 CFR part 63)
<b>Existing Stationary Engine &gt;500 HP Located at Area Sources of HAP</b>													
Emergency CI	Before 6/12/2006	5/3/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (f), (h), (i)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c))	Footnote 2 of Table 2d	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency CI	Before 6/12/2006	5/3/2013	63.6603 Table 2d	63.6603 Table 2b	>300 HP with displacement <30 l/cyl: 63.6604	63.6612 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(a), (b), (g), (h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e) and (f))	63.6650 (except 63.6650(g))	Yes
Emergency SI	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (f), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c))	Footnote 2 of Table 2d	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency SI 4SLB (that operate <b>more than</b> 24 hours per year)	Before 6/12/2006	10/19/2013	63.6603 Table 2d	63.6603 Table 2b	No Requirements	63.6612 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(a), (b), (h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e) and (f))	63.6650 (except 63.6650(g))	Yes
Non-Emergency SI 4SLB (that operate <b>24 hours or less</b> per year)	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency SI 2SLB	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency SI 4SRB (that operate <b>more than</b> 24 hours per year)	Before 6/12/2006	10/19/2013	63.6603 Table 2d	63.6603 Table 1b	No Requirements	63.6612 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(a), (b), (h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e) and (f))	63.6650 (except 63.6650(g))	Yes
Non-Emergency SI 4SRB (that operate <b>24 hours or less</b> per year)	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency Landfill/Digester Gas	Before 6/12/2006	10/19/2013	63.6603 Table 2d	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Residential/Commerical/Institutional Emergency CI	Before 6/12/2006	5/3/2013	These engines are subject to the requirements in 40 CFR 63.6640(f). No other requirements apply.										
Residential/Commerical/Institutional Emergency SI	Before 6/12/2006	10/19/2013	These engines are subject to the requirements in 40 CFR 63.6640(f). No other requirements apply.										

<sup>a</sup>Note that certain engines covered under 40 CFR part 63, subpart ZZZZ, may be subject to additional requirements under 40 CFR part 60, subparts IIII and JJJJ.

<sup>b</sup>For assistance in determining the potential to emit, please refer to <http://www.epa.gov/ttn/chief/ap42/index.html> or contact your EPA regional office or state permitting staff. To determine the potential to emit, you may use emission factors from <http://www.epa.gov/ttn/chief/ap42/ch03/index.html>, test data, or other published information.

<sup>c</sup>Note emergency engines have to comply with the definition of an emergency stationary RICE, which includes being operated per the requirements in 40 CFR 63.6640(f).

**Abbreviations:**

- CI-Compression Ignition
- SI-Spark Ignition
- 4SLB-4 Stroke Lean Burn
- 2SLB-2 Stroke Lean Burn
- 4SRB-4 Stroke Rich Burn

Engine Category	Date Constructed	Emission Limitations	Operating Limitations	Fuel Requirements	Performance Tests	Monitoring, Installation, Collection, Operation and Maintenance Requirements	Initial Compliance	Continuous Compliance	Notification Requirements	Recordkeeping Requirements	Reporting Requirements	General Provisions (40 CFR part 63)
<b>Stationary RICE at Area Sources</b>												
<b>STEP 1b - New &amp; Reconstructed Area Sources</b>												
<b>New &amp; Reconstructed Stationary Engine ≤500 HP Located at Area Source of HAP</b>												
Limited Use	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart IIII (CI NSPS) or subpart JJJJ (SI NSPS), as applicable.
Emergency	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart IIII (CI NSPS) or subpart JJJJ (SI NSPS), as applicable.
Non-Emergency CI	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart IIII (CI NSPS)
SI 4SLB	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)
SI 2SLB	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)
SI 4SRB	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)
Landfill/Digester Gas	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)
<b>New &amp; Reconstructed Stationary Engine &gt;500 HP Located at Area Source of HAP</b>												
Limited Use	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart IIII (CI NSPS) or subpart JJJJ (SI NSPS), as applicable.
Emergency	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart IIII (CI NSPS) or subpart JJJJ (SI NSPS), as applicable.
Non-Emergency CI	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart IIII (CI NSPS)
SI 4SLB	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)
SI 2SLB	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)
SI 4SRB	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)
Landfill/Digester Gas	On or After 6/12/2006											Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)

<sup>a</sup>Note that certain engines covered under 40 CFR part 63, subpart ZZZZ, may be subject to additional requirements under 40 CFR part 60, subparts IIII and JJJJ.

<sup>b</sup>For assistance in determining the potential to emit, please refer to <http://www.epa.gov/ttn/chief/ap42/index.html> or contact your EPA regional office or state permitting staff. To determine the potential to emit, you may use emission factors from <http://www.epa.gov/ttn/chief/ap42/ch03/index.html>, test data, or other published information.

**Abbreviations:**

- CI-Compression Ignition
- SI-Spark Ignition
- 4SLB-4 Stroke Lean Burn
- 2SLB-2 Stroke Lean Burn
- 4SRB-4 Stroke Rich Burn

Engine Category	Date Constructed	Compliance Date	Emission Limitations	Operating Limitations	Fuel Requirements	Performance Tests	Monitoring, Installation, Collection, Operation and Maintenance Requirements	Initial Compliance	Continuous Compliance	Notification Requirements	Recordkeeping Requirements	Reporting Requirements	General Provisions (40 CFR part 63)
<b>Stationary RICE at Major Sources</b>													
<b>STEP 2(a)(i)</b>													
<b>Existing Stationary Engine ≤500 HP Located at Major Source of HAP</b>													
Emergency CI	Before 6/12/2006	5/3/2013	63.6602 Table 2c	No Requirements	No Requirements	No Requirements	63.6625(e), (f), (h), (i)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c))	Footnote 1 of Table 2c	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency CI 100≤HP≤500	Before 6/12/2006	5/3/2013	63.6602 Table 2c	No Requirements	>300 HP with displacement <30 l/cyl: 63.6604	63.6612 63.6620 Table 4 Table 5	63.6625(h) ≥300 HP: 63.6625(g)	63.6630 Table 5	63.6605 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650(g))	Yes
Non-Emergency CI <100 HP	Before 6/12/2006	5/3/2013	63.6602 Table 2c	No Requirements	No Requirements	No Requirements	63.6625 (e), (h), (i)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Emergency SI	Before 6/12/2006	10/19/2013	63.6602 Table 2c	No Requirements	No Requirements	No Requirements	63.6625(e), (f), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c))	Footnote 1 of Table 2c	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency SI 4SLB 100≤HP≤500	Before 6/12/2006	10/19/2013	63.6602 Table 2c	No Requirements	No Requirements	63.6612 63.6620 Table 4 Table 5	63.6625(h)	63.6630 Table 5	63.6605 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650(g))	Yes
Non-Emergency SI 4SLB <100 HP	Before 6/12/2006	10/19/2013	63.6602 Table 2c	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency SI 2SLB 100≤HP≤500	Before 6/12/2006	10/19/2013	63.6602 Table 2c	No Requirements	No Requirements	63.6612 63.6620 Table 4 Table 5	63.6625(h)	63.6630 Table 5	63.6605 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650(g))	Yes
Non-Emergency SI 2SLB <100 HP	Before 6/12/2006	10/19/2013	63.6602 Table 2c	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency SI 4SRB 100≤HP≤500	Before 6/12/2006	10/19/2013	63.6602 Table 2c	No Requirements	No Requirements	63.6612 63.6620 Table 4 Table 5	63.6625(h)	63.6630 Table 5	63.6605 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650(g))	Yes
Non-Emergency SI 4SRB <100 HP	Before 6/12/2006	10/19/2013	63.6602 Table 2c	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).
Non-Emergency Landfill/Digester Gas 100≤HP≤500	Before 6/12/2006	10/19/2013	63.6602 Table 2c	No Requirements	No Requirements	63.6612 63.6620 Table 4 Table 5	63.6625(h)	63.6630 Table 5	63.6605 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650(g))	Yes
Non-Emergency Landfill/Digester Gas <100 HP	Before 6/12/2006	10/19/2013	63.6602 Table 2c	No Requirements	No Requirements	No Requirements	63.6625(e), (h), (j)	No Requirements	63.6605 63.6640	No Requirements	63.6655 (except 63.6655(c) and (f))	No Requirements	Yes, except per 63.6645(a)(5), the following do not apply: 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), and 63.9(b)-(e), (g) and (h).

Engine Category	Date Constructed	Compliance Date	Emission Limitations	Operating Limitations	Fuel Requirements	Performance Tests	Monitoring, Installation, Collection, Operation and Maintenance Requirements	Initial Compliance	Continuous Compliance	Notification Requirements	Recordkeeping Requirements	Reporting Requirements	General Provisions (40 CFR part 63)
<b>STEP 2(a)(ii)</b>													
<b>Existing Stationary Engine &gt;500 HP Located at Major Source of HAP</b>													
Limited Use	Before 12/19/2002	No Requirements											
Emergency	Before 12/19/2002	These engines are subject to the requirements in 40 CFR 63.6640(f). No other requirements apply.											
Non-Emergency CI	Before 12/19/2002	5/3/2013	63.6600(d) Table 2c	63.6600(d) Table 2b	>300 HP and <30 l/cyl:63.6604	63.6610 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(a), (b), (g), (h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650(g))	Yes
Non-Emergency SI 4SLB	Before 12/19/2002	6/15/2007	No Requirements										
Non-Emergency SI 2SLB	Before 12/19/2002	6/15/2007	No Requirements										
Non-Emergency SI 4SRB	Before 12/19/2002	6/15/2007	63.6600(a) Table 1a	63.6600(a) Table 1b	No Requirements	63.6610 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(a), (b), (h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650(g))	Yes
Landfill/Digester Gas	Before 12/19/2002	No Requirements											

<sup>a</sup>Note that certain engines covered under 40 CFR part 63, subpart ZZZZ, may be subject to additional requirements under 40 CFR part 60, subparts IIII and JJJJ.

<sup>b</sup>For assistance in determining the potential to emit, please refer to <http://www.epa.gov/ttn/chief/ap42/index.html> or contact your EPA regional office or state permitting staff. To determine the potential to emit, you may use emission factors from <http://www.epa.gov/ttn/chief/ap42/ch03/index.html>, test data, or other published information.

<sup>c</sup>Note emergency engines have to comply with the definition of an emergency stationary RICE, which includes being operated per the requirements in 40 CFR 63.6640(f).

Abbreviations:

CI-Compression Ignition  
SI-Spark Ignition  
4SLB-4 Stroke Lean Burn  
2SLB-2 Stroke Lean Burn  
4SRB-4 Stroke Rich Burn

Engine Category	Date Constructed	Compliance Date	Emission Limitations	Operating Limitations	Fuel Requirements	Performance Tests	Monitoring, Installation, Collection, Operation and Maintenance Requirements	Initial Compliance	Continuous Compliance	Notification Requirements	Recordkeeping Requirements	Reporting Requirements	General Provisions (40 CFR part 63)
<b>Stationary RICE at Major Sources</b>													
<b>STEP 2(b)(i)</b>													
<b>New &amp; Reconstructed Stationary Engine ≤500 HP Located at Major Source of HAP</b>													
Limited Use	On or After 6/12/2006	Engines are subject to 40 CFR part 60, subpart IIII (CI NSPS) or subpart JJJJ (SI NSPS), as applicable.											
Emergency	On or After 6/12/2006	Engines are subject to 40 CFR part 60, subpart IIII (CI NSPS) or subpart JJJJ (SI NSPS), as applicable.											
Non-Emergency CI	On or After 6/12/06	Engines are subject to 40 CFR part 60, subpart IIII (CI NSPS)											
SI 4SLB <250 HP	On or After 6/12/2006	Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)											
Non-Emergency SI 4SLB ≥250 HP	On or After 6/12/2006 and before 1/1/2008	No Requirements											
Non-Emergency SI 4SLB ≥250 HP	Manufactured on or after 1/1/2008	Upon Startup	63.6601 Table 2a	63.6601 Table 2b	No Requirements	63.6611 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650 (g))	Yes
Emergency SI 4SLB ≥250 HP	Manufactured on or after 1/1/2008	Upon Startup	No Requirements	No Requirements	No Requirements	No Requirements	63.6625(d), (h)	No Requirements	63.6605 63.6640	No Requirements	No Requirements	No Requirements	Yes
SI 2SLB	On or After 6/12/2006	Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)											
SI 4SRB	On or After 6/12/2006	Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)											
Landfill/Digester Gas	On or After 6/12/2006	Engines are subject to 40 CFR part 60, subpart JJJJ (SI NSPS)											

Engine Category	Date Constructed	Compliance Date	Emission Limitations	Operating Limitations	Fuel Requirements	Performance Tests	Monitoring, Installation, Collection, Operation and Maintenance Requirements	Initial Compliance	Continuous Compliance	Notification Requirements	Recordkeeping Requirements	Reporting Requirements	General Provisions (40 CFR part 63)
<b>STEP 2(b)(ii)</b>													
<b>New &amp; Reconstructed Stationary Engine &gt;500 HP Located at Major Source of HAP</b>													
Limited Use	On or After 12/19/2002	Upon Startup	No Requirements	No Requirements	No Requirements	No Requirements	No Requirements	No Requirements	63.6605	63.6645(f)	No Requirements	No Requirements	No (except as specified in 63.6645(f))
Emergency	On or After 12/19/2002	Upon Startup	No Requirements	No Requirements	No Requirements	No Requirements	No Requirements	No Requirements	63.6605 63.6640	63.6645(f)	No Requirements	No Requirements	No (except as specified in 63.6645(f))
Non-Emergency CI	On or After 12/19/2002	Upon Startup	63.6600(b) Table 2a	63.6600(b) Table 2b	No Requirements	63.6610 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(a), (b), (h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650 (g))	Yes
Non-Emergency SI 4SLB	On or After 12/19/2002	Upon Startup	63.6600(b) Table 2a	63.6600(b) Table 2b	No Requirements	63.6610 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(a), (b), (h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650 (g))	Yes
Non-Emergency SI 2SLB	On or After 12/19/2002	Upon Startup	63.6600(b) Table 2a	63.6600(b) Table 2b	No Requirements	63.6610 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(a), (b), (h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650 (g))	Yes
Non-Emergency SI 4SRB	On or After 12/19/2002	Upon Startup	63.6600(a) Table 1a	63.6600(a) Table 1b	No Requirements	63.6610 63.6615 63.6620 Table 3 Table 4 Table 5	63.6625(a), (b), (h), (k)	63.6630 Table 5	63.6605 63.6635 63.6640	63.6645	63.6655 (except 63.6655(c), (e), and (f))	63.6650 (except 63.6650 (g))	Yes
Landfill/Digester Gas	On or After 12/19/2002	Upon Startup	No Requirements	No Requirements	No Requirements	No Requirements	≥10 percent of the gross heat input on an annual basis: 63.6625(c), (h)	No Requirements	63.6605	≥10 percent of the gross heat input on an annual basis: 63.6645(f)	≥10 percent of the gross heat input on an annual basis: 63.6655(c)	≥10 percent of the gross heat input on an annual basis: 63.6650(g)	No (except as specified in 63.6645(f))

<sup>a</sup>Note that certain engines covered under 40 CFR part 63, subpart ZZZZ, may be subject to additional requirements under 40 CFR part 60, subparts IIII and JJJJ.

<sup>b</sup>For assistance in determining the potential to emit, please refer to <http://www.epa.gov/ttn/chief/ap42/index.html> or contact your EPA regional office or state permitting staff. To determine the potential to emit, you may use emission factors from <http://www.epa.gov/ttn/chief/ap42/ch03/index.html>, test data, or other published information.

<sup>c</sup>Note emergency engines have to comply with the definition of an emergency stationary RICE, which includes being operated per the requirements in 40 CFR 63.6640(f).

**Abbreviations:**

- CI-Compression Ignition
- SI-Spark Ignition
- 4SLB-4 Stroke Lean Burn
- 2SLB-2 Stroke Lean Burn
- 4SRB-4 Stroke Rich Burn